

The device

IV Produkt AB
Series
Envistar Compact
Envistar Flex and Flexomix
Envistar Top

a product of
IV Produkt AB
Sjöddevägen 7, 352 46 Växjö, Sweden

conforms the hygiene requirements of the guideline
VDI 6022 sheet 1 (July 2011)
Ventilation and indoor-air quality; Hygiene requirements
for ventilation and air-conditioning systems and units.

The conformity inspection was passed by test units installed at IV Produkt
AB in Växjö and by sample sets of the local production.

Additionally Installation and User Instructions have been checked.

Audit period: June – December 2016.


The test parameters and results are available on test reports 6142p4,
6142p5 and 6142p6 each of 20 December 2016.

This certificate also attests the conformity to the hygiene requirements
of VDI 3803 (February 2010) and DIN EN 13779 (September 2007) at
the time of inspection. The certificate is valid for identical devices until
November 2019, subject to any changes to the design or materials used.

SYNLAB  **SYNLAB**
Umweltinstitut GmbH
Standort Essen

Frillendorfer Straße 154, 45139 Essen
Tel. 02 01-2 01 87-0, Fax 02 01-2 01 87-11

Essen, 20 December 2016


Hans Joachim Oldenburg
Location Manager Hygiene Institute Essen

